



**BUREAU  
VERITAS**

**Bureau Veritas  
Consumer Products Services  
Germany GmbH**

Businesspark A96  
86842 Türkheim  
Germany  
+ 49 (0) 40 740 41 – 0  
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH  
Accredited according to EN 45011 -  
ISO / IEC Guide 65

## Certificate of compliance

**Applicant:** **Schneider Electric Solar Inverters USA, Inc.**  
250 South Vasco Road,  
Livermore, California 94551  
**USA**

**Product:** **Grid-tied photovoltaic inverter**

**Model:** **Conext TL 8000E**  
**Conext TL 10000E**

### Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2008 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

### Applied rules and standards:

#### IEC 61727:2004

Photovoltaic (PV) systems – Characteristics of the utility interface

#### IEC 62116:2008

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

#### IEEE 1547:2003 and 1547.1:2005

IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems

#### AS 4777.2:2005 and AS 4777.3:2005

Grid connection of energy systems via inverters – inverter requirements and grid protection requirements

*The following deviations for Thailand were applied according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA 2013):*

*under voltage limit (level 1): 198,0V*  
*under voltage limit (level 2): 110,0V*  
*over voltage limit (level 1): 242,0V*  
*overvoltage limit (level 2): 264,0V*  
*lower frequency limit: 48,0Hz*  
*upper frequency limit: 51,0Hz*  
*loss of main detection limit: 300ms*

*Metropolitan Electricity Authority (MEA 2013):*

*under voltage limit (level 1): 200,0V*  
*under voltage limit (level 2): 115,0V*  
*over voltage limit (level 1): 240,0V*  
*overvoltage limit (level 2): 310,0V*  
*lower frequency limit: 49,0Hz*  
*upper frequency limit: 51,0Hz*  
*loss of main detection limit: 300ms*

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** **PV130923C11**  
**PV130923C11-1**

**Certificate number:** **U13-0804**

**Date of issue:** **2013-11-14**


**Valid until:**

**2016-11-13**

### Certification body



QUALITY



HEALTH AND SAFETY

Dieter Zitzmann



ENVIRONMENT



Deutsche  
Akkreditierungsstelle  
D-ZE-12024-01-01

SOCIAL  
ACCOUNTABILITY