

Certificate No.: SGS/110906

CERTIFICATE OF COMPLIANCE

This certificate is issued to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has certified the equipment / appliance / accessory described hereunder to comply with the minimum safety standards for which the Application has been made by :-

SCHNEIDER ELECTRIC (AUSTRALIA) PTY LTD
33-37 Port Wakefield Road
GEPPS CROSS SA 5094
AUSTRALIA

DESCRIPTION OF ELECTRICAL EQUIPMENT

Class:	Energy System												
Product:	Solar (PV) Inverter												
Trade Name / Manufacturer:	CLIPSAL by Schneider Electric												
Catalogue / Model No(s):	Conext TL 15000E; Conext TL 20000E												
Ratings:	<table border="0"> <tr> <td>Input:-</td> <td>200-1000 V d.c.; 1000V max.; IP65; Class I;</td> </tr> <tr> <td></td> <td>Conext TL 15000E: 23 A per input;</td> </tr> <tr> <td></td> <td>Conext TL 20000E: 30 A per input</td> </tr> <tr> <td>Output:-</td> <td>230V a.c.; 50 Hz;</td> </tr> <tr> <td></td> <td>Conext TL 15000E: 24 A, 15000 W;</td> </tr> <tr> <td></td> <td>Conext TL 20000E: 32 A, 20000 W</td> </tr> </table>	Input:-	200-1000 V d.c.; 1000V max.; IP65; Class I;		Conext TL 15000E: 23 A per input;		Conext TL 20000E: 30 A per input	Output:-	230V a.c.; 50 Hz;		Conext TL 15000E: 24 A, 15000 W;		Conext TL 20000E: 32 A, 20000 W
Input:-	200-1000 V d.c.; 1000V max.; IP65; Class I;												
	Conext TL 15000E: 23 A per input;												
	Conext TL 20000E: 30 A per input												
Output:-	230V a.c.; 50 Hz;												
	Conext TL 15000E: 24 A, 15000 W;												
	Conext TL 20000E: 32 A, 20000 W												
Standard No.:	AS/NZS 3100:2009 + A1 with AS 4777.2:2005 and AS 4777.3:2005												

MARKING:	SGSE/110906
EXPIRY DATE:	03 January 2017
DATE OF CERTIFICATION:	04 January 2012



www.jas-anz.org/register



For and On Behalf of
SGS Systems & Services Certification Pty Ltd

