



# Certificate of Compliance

**Certificate:** 1473207

**Master Contract:** 159409

**Project:** 2336954

**Date Issued:** September 17, 2010

**Issued to:** Xantrex Technology Inc  
161 South Vasco Rd, Suite G  
Livermore, CA 94551  
USA  
Attention: Jim Eichner

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Brij Aggarwal*

**Issued by:** Brij Aggarwal, P.Eng

## **PRODUCTS**

**CLASS 5311 09** - POWER SUPPLIES - Distributed Generation Power Systems Equipment  
**CLASS 5311 89** - POWER SUPPLIES - Distributed Generation - Power Systems Equipment  
- Certified to U.S. Standards

Control panel, model "System Control Panel" for use with inverters, battery chargers, and other power conversion equipment and accessories; Class 2 ELV input rated 15 V dc, 200 mA.

### Notes:

1. Evaluated for use in general applications including marine and recreational vehicle installations.
2. Rated for use in ambient temperatures up to 50°C.

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No 107.1-01 - General Use Power Supplies

UL 458 - 5th Ed - Power Converters/Inverters and Power Converter/Inverter Systems for Land Vehicles and Marine Crafts