



SGS EPCS – A consistent, prompt & competent electrical product approvals service

17 December 2013

K. Ajith Kumar
SCHNEIDER ELECTRIC SOLAR INVERTERS USA, INC
250 South Vasco Road
Livermore, California 94551
USA

Cc/ Bureau Veritas Consumer Products Services (H.K.) Ltd.

Dear K. Ajith Kumar,

CERTIFICATE OF COMPLIANCE OF ELECTRICAL EQUIPMENT

Enclosed is the Certificate of Compliance in respect to your recent application for certification received by SGS Electrical Product Certification Services (EPCS).

Please take the time to check the certificate and ensure all details are correct in accordance with your application.

The marking as specified on the certificate is optional (although preferred) as this is classified as non-prescribed electrical equipment. Alternatively, the regulatory compliance mark (RCM) may be used in accordance with its conditions of use as set out in AS/NZS 4417.1.

Please note that it is a requirement that if you modify the electrical equipment in any way, you are required to notify EPCS of the details of the modifications for compliance. You should complete and submit form EPCS-F01, detailing the changes.

Should you have any queries, please contact myself.

Yours sincerely,

Darren McNamara
Manager – SGS Electrical Product Certification Services
SGS Systems & Services Certification Pty Ltd

Certificate No.: SGS/131128

CERTIFICATE OF COMPLIANCE

This certificate is equivalent to a Certificate of Suitability and is issued to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has certified the article described herein to comply with the minimum safety standards for which the Application has been made by :-

SCHNEIDER ELECTRIC SOLAR INVERTERS USA, INC
250 South Vasco Road
Livermore, California 94551
USA

DESCRIPTION OF ELECTRICAL EQUIPMENT

Product:	Solar (PV) Inverter (Grid Connected Inverter)				
Trade Name / Manufacturer:	Schneider Electric				
Catalogue / Model No(s):	Conext TL 8000E; Conext TL 10000E				
Ratings:	<table border="0"> <tr> <td>Input:</td> <td>200-1000 V d.c.; (MPPT 350-850 V d.c.); 2 x Max. 24 A; Class I; IP55</td> </tr> <tr> <td>Output:</td> <td>230 V a.c. / 400 V a.c. (3/N/PE); 50 Hz; Conext TL 8000E: 12.8 A, 8000 VA; Conext TL 10000E: 16 A, 10000 VA</td> </tr> </table>	Input:	200-1000 V d.c.; (MPPT 350-850 V d.c.); 2 x Max. 24 A; Class I; IP55	Output:	230 V a.c. / 400 V a.c. (3/N/PE); 50 Hz; Conext TL 8000E: 12.8 A, 8000 VA; Conext TL 10000E: 16 A, 10000 VA
Input:	200-1000 V d.c.; (MPPT 350-850 V d.c.); 2 x Max. 24 A; Class I; IP55				
Output:	230 V a.c. / 400 V a.c. (3/N/PE); 50 Hz; Conext TL 8000E: 12.8 A, 8000 VA; Conext TL 10000E: 16 A, 10000 VA				
Standard No.:	AS/NZS 3100:2009 + A1 + A2 AS 4777.2:2005 and AS 4777.3:2005				

REQUIRED MARKING:	SGS-131128-E
EXPIRY DATE:	16 December 2018
DATE OF CERTIFICATION:	17 December 2013

JAS-ANZ



www.jas-anz.org/register

For and On Behalf of
SGS Systems & Services Certification Pty Ltd

