



APPROVALS®

Certificate of Approval

Certificate No.: SAA101174

Date of Issue: 20 March 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

Certificate Holder:

Schneider Electric (Australia) Pty Ltd
33-37 Port Wakefield Road
Gepps Cross SA 5094
Australia

Class Description:
Product Description:
Brand Name:
Model No.:
Markings:

Non-Declared
Grid Connected, Hybrid Inverter Charger
Schneider Electric XW ser
XW6048-230-50
Input: 42-60Vdc, Max 160A
Output: 230V 50Hz 6000VA

Standard:

AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009

Conditions:

Nil

Approval Mark:

SAA101174 or RCM

Date First Registered:

20 October 2010

Date of Expiry:

20 October 2015


For and on Behalf of

SAA Approvals Pty Ltd

Certificate transferred to new certificate holder.



JAS-ANZ



www.jas-anz.org/register



APPROVALS®

Certificate of Approval

Addendum

Certificate No.: SAA101174

Date of Issue: 20 October 2010

Class Description: Non-Declared

Product Description: Grid Connected Inverter

Additional Models

XW4548-230-50

Description

Similar to model XW6048-230-50 except for invert mode rated input: 42-60Vdc 120A max, output: 230V 50Hz 4500VA.

XW4024-230-50

Similar to model XW6048-230-50 except for invert mode rated input: 21-30Vdc 220A max, output: 230V 50Hz 4000VA.

For and on Behalf of

SAA Approvals Pty Ltd

Certificate reissued 22 March 2012 to amend format.

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum safety requirements for which the application has been made.

JAS-ANZ

