

Certificate No.: SGS/130660

CERTIFICATE OF COMPLIANCE

This certificate is issued to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has certified the article described herein to comply with the minimum safety standards for which the Application has been made by :-

SCHNEIDER ELECTRIC SOLAR INVERTERS USA, INC
250 South Casco Road
Livermore, California 94551
USA

DESCRIPTION OF ELECTRICAL EQUIPMENT

Product:	Solar Inverter (Grid-Tied Photovoltaic Inverter)																
Trade Name / Manufacturer:	Schneider Electric																
Catalogue / Model No(s):	Conext RL 3000E; Conext RL 3000E-S; Conext RL 4000E; Conext RL 4000E-S; Conext RL 5000E; Conext RL 5000E-S																
Ratings:	<table border="0"> <tr> <td>Input:</td> <td>90-550 V d.c.; Class I; IP65</td> </tr> <tr> <td></td> <td>Conext RL 3000E, Conext RL 3000E-S: (MPPT 160-500 V d.c.), 10 A;</td> </tr> <tr> <td></td> <td>Conext RL 4000E, Conext RL 4000E-S: (MPPT 180-500 V d.c.), 12 A;</td> </tr> <tr> <td></td> <td>Conext RL 5000E, Conext RL 5000E-S: (MPPT 180-500 V d.c.), 18 A</td> </tr> <tr> <td>Output:</td> <td>230 V a.c.; 50 Hz</td> </tr> <tr> <td></td> <td>Conext RL 3000E, Conext RL 3000E-S: 13.9 A, 3 kVA;</td> </tr> <tr> <td></td> <td>Conext RL 4000E, Conext RL 4000E-S: 18.2 A, 4 kVA;</td> </tr> <tr> <td></td> <td>Conext RL 5000E, Conext RL 5000E-S: 23.2 A, 5 kVA</td> </tr> </table>	Input:	90-550 V d.c.; Class I; IP65		Conext RL 3000E, Conext RL 3000E-S: (MPPT 160-500 V d.c.), 10 A;		Conext RL 4000E, Conext RL 4000E-S: (MPPT 180-500 V d.c.), 12 A;		Conext RL 5000E, Conext RL 5000E-S: (MPPT 180-500 V d.c.), 18 A	Output:	230 V a.c.; 50 Hz		Conext RL 3000E, Conext RL 3000E-S: 13.9 A, 3 kVA;		Conext RL 4000E, Conext RL 4000E-S: 18.2 A, 4 kVA;		Conext RL 5000E, Conext RL 5000E-S: 23.2 A, 5 kVA
Input:	90-550 V d.c.; Class I; IP65																
	Conext RL 3000E, Conext RL 3000E-S: (MPPT 160-500 V d.c.), 10 A;																
	Conext RL 4000E, Conext RL 4000E-S: (MPPT 180-500 V d.c.), 12 A;																
	Conext RL 5000E, Conext RL 5000E-S: (MPPT 180-500 V d.c.), 18 A																
Output:	230 V a.c.; 50 Hz																
	Conext RL 3000E, Conext RL 3000E-S: 13.9 A, 3 kVA;																
	Conext RL 4000E, Conext RL 4000E-S: 18.2 A, 4 kVA;																
	Conext RL 5000E, Conext RL 5000E-S: 23.2 A, 5 kVA																
Standard No.:	AS/NZS 3100:2009 + A1 + A2 AS 4777.2:2005 and AS 4777.3:2005																

REQUIRED MARKING: SGS-130660-E
EXPIRY DATE: 07 August 2018
DATE OF CERTIFICATION: 08 August 2013

JAS-ANZ



www.jas-anz.org/register

[Signature]

For and On Behalf of
SGS Systems & Services Certification Pty Ltd

