



**Intertek Testing Services Taiwan Ltd.**  
5F, No. 423, Ruiguang Road, Neihu District,  
Taipei 114, Taiwan  
Tel.: (+886-2) 6602 2888  
Fax: (+886-2) 6602 2415

## Test Verification of Conformity

**On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.**

**Applicant Name & Address** : Xantrex Technology Inc.  
161-G South Vasco Road Livermore, California USA 94551

**Product(s) Tested** : PV Inverter

**Ratings and principal characteristics** : Input: 200-1000 Vdc, Max. input current: 30 A per input  
Output Voltage: 3 phase 230 Vac, 50/ 60 Hz  
Max. output power: 20000 VA  
Max. output current: 32 A/phase

**Model(s)** : Conext TL 20000 E, Conext TL 15000 E

**Brand name** : Schneider

**Relevant Standard(s)/Specification(s)** : AS/NZS 61000.6.3: 2007 / AS/NZS 61000.6.4: 2007  
AS/NZS CISPR 14.1: 2010  
AS/NZS 61000.3.12: 2006  
AS/NZS 61000.3.11: 2002  
AS/NZS 61000.6.2: 2006 / AS/NZS 61000.6.1: 2006  
IEC 61000-4-2: 2008  
IEC 61000-4-3: 2010  
IEC 61000-4-4: 2011  
IEC 61000-4-5: 2005  
IEC 61000-4-6: 2008  
IEC 61000-4-8: 2009  
IEC 61000-4-11: 2004

NOTE: The equipment covered by this document is subject to mandatory compliance with - the European EMC Directive, 2004/108/EC.

**Verification Issuing Office Name & Address** : Intertek Testing Services Taiwan Ltd.  
No. 11, Lane 275, Ko-Nan 1 Street, Chia-Tung Li, Shiang-Shan District,  
Hsinchu City, Taiwan

**Verification/Report Number(s)** : TS11120023-EME (TS11120023-EME)

**NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.**

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



  
**ERIC CHU**  
**LABORATORY MANAGER**  
**DEC 13, 2011**

