



# Certificate of Compliance

**Certificate:** 2719006

**Master Contract:** 159409

**Project:** 70139766

**Date Issued:** 2017-06-29

**Issued to:** Schneider Electric Solar Inverters USA, Inc.  
250 S Vasco Road  
Livermore, California 94550  
USA

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Kyle Song  
Kyle Song

## **PRODUCTS**

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Transformerless Utility Interactive Inverter, Models Conext CL18000NA and Conext CL25000NA, 3 phase, permanently connected.

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record, Annex A, or the descriptive report.

## **APPLICABLE REQUIREMENTS**

- |   |   |  |
|---|---|--|
| CSA C22.2 No. 107.1-01                    | - | General Use Power Supplies   |
| *UL Std. No. 1741-2 <sup>nd</sup> Edition | - | Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources (Rev. September 7, 2016) |
| UL CRD                                    | - | Non-Isolated EPS Interactive PV Inverters Rated Less Than 30kVA  |
| UL 1699B                                  | - | Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue Number 2, January 14, 2013)                          |
| CSA TIL M-07                              | - | Interim Certification Requirements for Photovoltaic (PV) DC Arc Fault Protection (Issue Number 1, March 11, 2013)                          |



**Certificate:** 2719006  
**Project:** 70139766

**Master Contract:** 159409  
**Date Issued:** 2017-06-29

---

\*Note: Conformity to UL 1741-Second Edition (Rev. September 7, 2016) includes compliance with applicable requirements of IEEE 1547-2003 (R2008) and IEEE 1547.1-2005(R2011).