

## 1 Certificate of Conformity

**Product:** Grid-tied photovoltaic inverter

**Brand:** 

**Model:** Conext CL 20000 E, Conext CL 25000 E (Refer to item 3.2 for more details)

**Test Model:** Conext CL 25000 E

**Sample Status:** Mass-Production

**Applicant:** Schneider Electric Solar Inverters USA, Inc.

**Test Date:** Mar. 03, 2014 (Conducted emission test)  
May 16, 2014 (Radiated emission test)  
Jul. 30 ~ Aug. 06, 2014 (ESD, EFT, CS, PFMF tests)  
Aug. 25, 2014 (RS test)  
Sep. 05, 2014 (Surge test)  
Oct. 28, 2014 (Harmonics, Flicker tests)  
Nov. 13, 2014 (Conducted emission at telecom port test)

**Standards:** **EN 61000-6-3:2007 +A1:2011 +AC:2012 / IEC 61000-6-3:2011 ED. 2.1**  
**EN 61000-3-12:2011 / IEC 61000-3-12: 2011 ED. 2.0**  
**EN 61000-3-11:2000 / IEC 61000-3-11: 2000 ED. 1.0**  
**EN 61000-6-2:2005 +AC:2005 / IEC 61000-6-2:2005 ED. 2.0**  
EN 61000-4-2:2009 / IEC 61000-4-2:2008 ED. 2.0  
EN 61000-4-3:2006 +A1:2008 +A2:2010 / IEC 61000-4-3:2010 ED. 3.2  
EN 61000-4-4:2012 / IEC 61000-4-4:2012 ED. 3.0  
EN 61000-4-5:2006 / IEC 61000-4-5:2005 ED. 2.0  
EN 61000-4-6:2014 / IEC 61000-4-6:2013 ED. 4.0  
EN 61000-4-8:2010 / IEC 61000-4-8:2009 ED. 2.0  
EN 61000-4-11:2004 / IEC 61000-4-11:2004 ED. 2.0 (Not applicable)

We, **Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch**, declared that the equipment above has been found compliance with the requirement of applicable standards. The test record, data evaluation and Equipment Under Test (EUT) configurations represented herein are true and accurate under the standards herein specified.


**Prepared by :**

  
Maggie Wu / Specialist

**Date:**

Jan. 20, 2015

**Approved by :**

  
Ken Liu / Senior Manager

**Date:**

Jan. 20, 2015

Note: The EUT consumes DC power; therefore the standard EN 61000-4-11 was not tested.